

## **Brew Bay Improvement District Small Water System Emergency Response Plan**

**For the Year 2024-25**

<b>EMERGENCY CONTACT INFORMATION</b>			
<b>Area of Expertise</b>	<b>Contact Name(s)</b>	<b>Phone #</b>	<b>Alternative Contact Info</b>
<b>Primary Operator/Manager</b>	Mel Waldron	604-487-4294	
<b>Backup Operator</b>	Phillippe Beauchemin	604-414-9707	
<b>Backup Contacts</b>	Richard Neall	604-487-0960	
<b>Administration</b>	Brenda Neall	604-487-0960 / 604-414-4059	<a href="mailto:brewbayid@gmail.com">brewbayid@gmail.com</a>
<b>Emergency Call Committee Prime &amp; Backup</b>	Brenda Neall (Prime) Alice McNair (Backup)	604-487-0960 604-414-5733	
<b>Electrical</b>	Falcon Electric	604-485-5209	
	Patrick Dohm	604-487-4366	
<b>Mechanical &amp; Plumbing</b>	Mel Waldron	604-487-4294	
	Phillippe Beauchemin	604-414-9707	
	Bob Richardson	604-487-9705	
	Dan Neyts	604-487-4429	
<b>Equipment Supplier(s)</b> (Spares for water and chlorine pumps and compressor on hand)	Van Isle Water - Various	250-383-7145	
	Cleartech - Chlorine pump	1-800-387-7503	
	Culligan	403-516-8404	
	Hach - Paul Ing – Srv Mgr Chlorine & turbidity metering and monitoring	604-340-9100	
<b>Excavation Services:</b>	Large Backhoe - TBD		
	Mel Waldron	604-487-4294	
<b>Alternative Drinking Water Supplier:</b>	Aaron Service & Supplies	604-485-5611	
<b>Malaspina Fire Department</b>	Bill Ashworth – Deputy Fire Chief	604-487-9911	<a href="mailto:mvpdchief@gathet.ca">mvpdchief@gathet.ca</a>
<b>BC Hydro</b>	BC Hydro Outage Calls From a Cell Phone:	1-888-769-3766 *49376	
<b>City of Powell River (Weir)</b>	City of PR Water Maintenance Truck: Tim/Spence/John	604-483-6496	Emergency #: 604-483-1542
<b>Capilano Highways Services</b>	Primary: Tyler Lamber	604-414-3682 604-413-0911	CHS Head Office: 604-983-2411 1-800-665-3135 (Hotline)
<b>Ministry of Transportation &amp; Infrastructure</b>	Area Manager – Rino Parise	604-485-3610 604-483-1189	<a href="mailto:rino.parise@gov.bc.ca">rino.parise@gov.bc.ca</a>
<b>Powell River Regional District Emergency Services</b>	Ryan Thoms	604-485-2260 Cell: 604-414-4553	<a href="mailto:rthoms@gathet.ca">rthoms@gathet.ca</a>

## Brew Bay Improvement District Emergency Response Plan

PUBLIC HEALTH CONTACT INFORMATION				
<b>PRIMARY CONTACT</b>				
Jack Davidson <b>DWO</b>	604-485-3335	604-483-1981	604-314-0596	<a href="mailto:jack.davidson@vch.ca">jack.davidson@vch.ca</a>
<b>BACK-UP HEALTH CONTACTS</b>				
1.Darren Molder <b>DWO</b>	604-885-8711	604-989-1357	604-989-7678	<a href="mailto:darren.molder@vch.ca">darren.molder@vch.ca</a>
2.Michael Nguyen <b>DWO</b>	604-485-3324	604-414-5545	778-317-8567	<a href="mailto:michael.nguyen@vch.ca">michael.nguyen@vch.ca</a>
2.Dan Glover <b>DWO</b>	604-815-6846	604-815-3128	n.a.	<a href="mailto:dan.glover@vch.ca">dan.glover@vch.ca</a>
3.Phil Muirhead <b>DWO</b>	604-983-6756	604-306-2717	n.a.	<a href="mailto:phil.muirhead@vch.ca">phil.muirhead@vch.ca</a>
4.Moliehi Khaketla <b>MHO*</b>	604-984-5070	604-612-9433	n.a.	<a href="mailto:moliehi.khaketla1@vch.ca">moliehi.khaketla1@vch.ca</a>

**\*Note:** For the purpose of the Drinking Water Protection Act and Regulation, Dr. Moliehi Khaketla is both a Medical Health Officer and a Drinking Water Officer.

**DWO;** Drinking Water Officer

**MHO;** Medical Health Officer

Brew Bay Improvement District Board of Trustees Contact Information				
Name and Role	Phone #	Cell #'s	Other #'s	Email
<b>Trustee / Trustee Chair:</b> Melanie Jordan		604-916-8250	250-830-8470	<a href="mailto:mjordan@icloud.com">mjordan@icloud.com</a>
<b>Trustee</b> Ellena Johnson	604-733-2978	604-319-7771		<a href="mailto:ydm@shaw.ca">ydm@shaw.ca</a>
<b>Trustee</b> Phil Beauchemin		604-414-9707	604-414-5733	<a href="mailto:mcbeau3@shaw.ca">mcbeau3@shaw.ca</a>
<b>Admin</b> Brenda Neall	604-487-0960	604-414-4059		<a href="mailto:brendajneall@gmail.com">brendajneall@gmail.com</a>

## **EMERGENCY RESPONSE PROCEDURES:**

### **IN CASE OF EMERGENCY CONTACT:**

**Mel Waldron – 604-487-4294 OR Phillippe Beauchemin – 604-414-9707**

### **LOCATION OF WATER SOURCE (BREW BAY ID PUMPHOUSE):**

**2260 Brew Bay Road, Powell River, BC, V8A 0L2**

Directions to Site - Pump House is located at the corner of Highway 101 and Brew Bay Road:  
Turn off Highway 101 onto Brew Bay Road, which is on the north side of the Lang Creek Bridge.  
Turn in at the first driveway on the left just past the mailboxes.

### **EMERGENCY PROCEDURES:**

If the water in the water system becomes contaminated – i.e. receipt of an unsatisfactory water test result, or in the event of an interruption in the treatment process:

1. Contact the System Operator(s) (see info above for Mel Waldron or Phillippe Beauchemin) or if not available, contact backup person, Richard Neall
2. Shut off water supply, if appropriate (instructions posted in the pump house)
3. System Operator (Mel Waldron, Phillippe Beauchemin) will notify DWO (Jack Davidson) or back-up health contact (see Public Health Contact list).
4. System operator (Mel Waldron, Phillippe Beauchemin) will contact Brenda Neall, who heads the emergency telephone committee and also sends out any automated water system alerts via the BBID Website. Contact any other appropriate person(s) required. List of critical repair emergency numbers are included in the Emergency Contact info.
5. The Emergency Call Committee and/or Alert System messages will be used to notify affected water users. Operators to provide necessary updates if further member notification is required.
6. Mel Waldron and/or Phillippe Beauchemin, will coordinate repair
7. If necessary, an alternate source of safe drinking water will be procured

### **START UP PROCEDURE:**

1. Identify and correct source of contamination.
2. Entire system should be flushed and disinfected, following Small Water System operator guidelines.

## ***Brew Bay Improvement District Emergency Response Plan***

3. Submit water sample(s) to appropriate approved Lab for testing. For bacteriological contamination, three successive sampling results must be negative.
4. Contact DWO (Jack Davidson) for approval to resume normal use of water supply.

### **LOCATION OF EMERGENCY RESPONSE PLAN (ERP) Copies**

<b>Title</b>	<b>Name</b>	<b>Location</b>
Operator:	Mel Waldron	2149 Mahood Road
Operator:	Phillippe Beauchemin	10369 Patrick Road
Backup Contacts	Richard Neall	2107B Mahood Road
Telephone Committee:	list attached	Committee residences
Water Plant:	Brew Bay Road	See directions on Pg 3
Trustees & Officers:	Melanie Jordan (Chair) Ellena Johnson Phil Beauchemin Brenda Neall (Admin)	10401 Patrick Road 2121 Brew Bay Road 10369 Patrick Road 2107B Mahood Road
Website:	Brew Bay Improvement District	<a href="https://brewbayid.ca/emergency-response-plan">https://brewbayid.ca/emergency-response-plan</a>

### **SUPPLEMENTARY DOCUMENTS**

Printed copies of these documents are included in printed versions of the plan.  
The documents included are:

- ☐ Emergency Call Committee – List of Primary and Backup Persons
- ☐ Boil Water Advisory Notice
- ☐ Do Not Use Water Notice

<b>Brew Bay Improvement District Emergency Call Committee Primary &amp; Backup List</b>					
<b>**Emergency Call Committee Prime - **Brenda Neall / Brenda's Backup - **Alice McNair</b>					
	<b>Group 1</b>	<b>Group 2</b>	<b>Group 3</b>	<b>Group 4</b>	<b>Group 5</b>
<b>Primary Call Persons</b>	<b>Odette Coccola</b> 10389 Patrick Road 250-882-0460 ococcola@gmail.com	<b>Heather Stonehouse</b> 2120 Mahood Road 604-487-1375 russ9889@telus.net	<b>**Alice (Norah-Lee) McNair</b> 10369 Patrick Road 604-414-5733 alice.mcnaair@shaw.ca	<b>Colleen Lang</b> 2254 Zilinsky Road 604-223-1697 alclang@shaw.ca	<b>Mimi Richardson</b> 10409 Croft Road 604-487-9705/604-223-1146 mimirichardson@shaw.ca
<b>Backup Call Persons</b>	<b>Jeanette Scott</b> 10332 Patrick Road 604-487-0750/ 604-223-3684 bandj@shaw.ca	<b>Karin Birch-Cromar</b> 10420 Patrick Road 604-487-0140 karinb7@shaw.ca	<b>**Brenda Neall</b> 2107B Mahood Road 604-487-0960/604-414-4059 brendajneall@gmail.com	<b>**Brenda Neall</b> 2107B Mahood Road 604-487-0960/604-414-4059 brendajneall@gmail.com	<b>Ellena Johnson</b> 2121 Brew Bay Road 604-319-7771/604-733-2978 ydm@shaw.ca

## **BOIL WATER ADVISORY**

The Brew Bay Improvement District Water System is advising all users to boil their water before using it for drinking, cooking, washing food, or brushing teeth, due to a potential problem with the water system.

The water can be made safe by boiling it for at least two minutes at a rolling boil. Boiled water should be stored in a clean container in the refrigerator.

Alternatively, bottled water can be used.

You will be notified when service is returned to normal and the water is again safe to drink.

Thank you for your co-operation in this matter.



PHI014

# **DO NOT USE WATER NOTICE**

**The Brew Bay Improvement  
District Water System**

**IS ADVISING ALL USERS THAT  
THE DOMESTIC WATER SUPPLY  
IS NOT SAFE FOR DRINKING OR  
DOMESTIC USE.**

**DUE TO THE NATURE OF THE  
CONTAMINATION, BOILING MAY NOT  
ACHIEVE SAFE DRINKING WATER**



PH014