



## HEALTH PROTECTION

# PERMIT TO OPERATE

A Community Water System 15-300 Connections

Purveyor: Brew Bay Improvement District  
Facility Name: Brew Bay Improvement District Water System  
Facility Number: 1110442

### Conditions of Permit

- Ensure Emergency Response Plan is updated as required.
- Continue to monitor free chlorine residuals in distribution system on a regular basis and submit bacteriological water samples regularly.
- Submit your annual report for 2018 by June 2019 to VCH

March 1, 1995  
Effective Date

  
Drinking Water Officer

May 3, 2018  
Revised Date

This permit must be displayed in a conspicuous place and is not transferable