

Sample Range Report

Vancouver Coastal Health

Facility Name: Brew Bay Improvement District Water System

Date Range: Jan 1 2018 to Dec 31 2018

Operator Brew Bay Improvement District
10475 Patrick Rd.
Powell River, BC V8A 0L1

<u>Sampling Site</u>	<u>Date Collected</u>	<u>Total Coliform</u>	<u>E. Coli</u>	<u>Fecal Coliform</u>
<u>Waldron Residence</u>				
<u>10475 Patick Rd.,</u>				
<u>Brew Bay</u>				
	1/2/2018	L1	L1	
	1/16/2018	L1	L1	
	1/30/2018	L1	L1	
	2/13/2018	L1	L1	
	2/27/2018	L1	L1	
	3/13/2018	L1	L1	
	3/27/2018	L1	L1	
	4/10/2018	L1	L1	
	4/25/2018	L1	L1	
	6/5/2018	L1	L1	
	6/20/2018	L1	L1	
	7/17/2018	L1	L1	
	7/31/2018	L1	L1	
	8/15/2018	L1	L1	
	8/29/2018	L1	L1	
	9/11/2018	L1	L1	
	10/23/2018	L1	L1	
	11/7/2018	L1	L1	
	11/20/2018	L1	L1	
	12/5/2018	L1	L1	
	12/18/2018	<u>L1</u>	<u>L1</u>	
	Total Positive:	0	0	

Pumphouse -
Outside (treated).
Brew Bay

	1/2/2018	L1	L1	
	1/16/2018	L1	L1	
	1/30/2018	L1	L1	
	2/13/2018	L1	L1	
	2/27/2018	L1	L1	
	3/13/2018	L1	L1	
	3/27/2018	L1	L1	
	4/10/2018	L1	L1	
	4/25/2018	L1	L1	
	6/5/2018	L1	L1	
	6/20/2018	6	L1	

7/17/2018	L1	L1
7/31/2018	L1	L1
8/15/2018	L1	L1
8/29/2018	L1	L1
9/11/2018	L1	L1
10/23/2018	L1	L1
11/7/2018	L1	L1
11/20/2018	L1	L1
11/28/2018	L1	L1
12/5/2018	L1	L1
12/18/2018	<u>L1</u>	<u>L1</u>
Total Positive:	1	0

Neall Residence,
2107B Mahood Rd.,
Powell River, BC

1/2/2018	L1	L1
1/16/2018	L1	L1
1/30/2018	L1	L1
2/13/2018	L1	L1
2/27/2018	L1	L1
3/13/2018	L1	L1
3/27/2018	L1	L1
4/10/2018	L1	L1
4/25/2018	L1	L1
6/5/2018	1	L1
6/20/2018	L1	L1
7/17/2018	L1	L1
7/31/2018	L1	L1
8/15/2018	L1	L1
8/29/2018	L1	L1
9/11/2018	L1	L1
10/23/2018	L1	L1
11/7/2018	L1	L1
11/20/2018	L1	L1
12/5/2018	L1	L1
12/18/2018	<u>L1</u>	<u>L1</u>
Total Positive:	1	0

Result Values: E - estimated L - less than G - greater than

Samples that contain total coliform:	2		3.12% of total
Samples that contain e. coli:	0		0.00% of total
Samples that contain fecal coliform:	0		0.00% of total
Number of consecutive samples that contain total coliform:	0		
Number of samples that contain total coliform in last 30 days:	0/0		
Total number of samples:	64		

Comments:

Environmental Health Officer

Apr 9 2019

FOR FURTHER INFORMATION PLEASE CALL: Michael Nguyen